

NESCO UTILITY

Corporate Office: Januganj, Balasore – 756019, Odisha.

Ph-06782-269864, Fax No: 06782-263259.

FC/CO/232/ 10732 (5)

Dated:- 19.9.16

To

The Superintending Engineer
Electrical Circle, Keonjhar

Sub: - Permission for enhancement of Contract Demand from 255 KVA to 4200 KVA in favor of M/s Ardent Steel Ltd at 33KV supply system.

Ref:- Your letter No 2515 dated 09.09.2016

Sir,

With reference to the application of M/s Ardent Steel Ltd for availing power supply with enhanced Contract Demand of 4200 KVA (from 255 KVA) and as per your recommendation under reference, Permission is hereby accorded in favor of M/s Ardent Steel Ltd, At- Phuljhar, Via-Suakati, Bansapal, Keonjhar for availing power supply with enhanced contract demand of 4200 KVA (from 255 KVA) at 33 KV supply system subject to the following terms and conditions:

1. Contract Demand shall be 4200 KVA (enhanced from 255 KVA).
2. The consumer shall declare his connected load and supposed to install Maximum Demand Controller Relay in order to avoid any overdrawl above 120% of permitted load, failing which this may attract action under 126 of IE Act 2003.
3. Supply voltage will be 33 KV.
4. Tariff shall be as applicable under "Large Industrial Category (HT)".
5. The consumer shall install a suitable rated capacitor to keep overall power factor not below 92%.
6. Existing metering arrangement is to be checked and if required the same is to be replaced by suitable capacity 33KV metering cubicle and similar capacity metering unit for check metering purpose along with HT TV meter and AMR modem. The consumer has to bear the cost of all metering equipments. Necessary estimate in this regard shall be furnished by EE, KED, Keonjhar separately.
7. It is to be ensured that no overhead line of NESCO is passing through the premises of the consumer. The substation as well as the 33 KV equipments should be installed at least 50 meter away from the line passing outside the premises of the consumer. It must be ensured that there is no other source of power supply from other premises.
8. The consumer shall execute an agreement in form No-3 of OERC Distribution (Conditions of Supply) Code 2004 now in force in corporate office, NESCO Utility, Balasore after deposit of **Additional Security Deposit of Rs 1, 98, 30,410.00 (Rupees One Crore Ninety Eight lac Thirty thousand Four hundred Ten only)**, Inspection report from Electrical Inspector and test report from licensed contractor and required service connection charges.


19/9

9. In the event of theft of electricity by any means detected in course of checking/testing by NESCO officials, Power supply will be disconnected. The power supply will be reconnected after realization of the penal bill if any.
10. NESCO officials can enter into the industrial premises of the consumer at any point of time as and when required for checking or testing purpose. If it is obstructed, Power supply to the unit is liable for disconnection without notice.
11. All rules and regulations of OERC Distribution (Condition of Supply) Code'2004 and any other legal and statutory conditions applicable to the industry shall be observed before effecting enhanced load.
12. This permission letter is valid for 30 days from the date of issue of this letter.

Yours faithfully,


General Manager (Commerce)

- C.C to EE (MRT), Keonjhar for information and necessary action
- C.C to Executive Engineer, KED, Keonjhar for information and necessary action
- C.C to DGM (MRT), Corporate Office, NESCO for information and necessary action
- C.C M/s Ardent Steel Ltd, At- Phuljhar, Via-Suakati, Bansapal, Keonjhar in response to his application for availing enhanced load of 4200 KVA in 33 KV.